



CERTIFICATE OF APPROVAL

No CF 462

This is to certify that, in accordance with
TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

DIXON INTERNATIONAL GROUP LTD

(Sealmaster is a division of DIG Ltd)

Brewery Road, Pampisford, Cambridge CB22 3HG
TEL: 01223 832851

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:

CERTIFIED PRODUCT

Sealmaster Intumescent Fire and
Smoke Seals

TECHNICAL SCHEDULE

TS35 – The Contribution of
Intumescent Seals to the Fire
Resistance of Pedestrian
Type Door Assemblies
TS21 – The Contribution of
Edge Seals to the Control of
Smoke Leakage via Door
Assemblies

Signed and sealed for and on behalf of Warringtonfire Testing and Certification Limited

Paul Duggan
Certification Manager



Issued: 16th March 2006
Reissued: 18th April 2019
Next audit test due: 18th April 2020
Frequency: Annually
Valid to: 17th April 2024





CERTIFICATE No CF 462
DIXON INTERNATIONAL GROUP LTD
(Sealmaster is a division of DIG Ltd)

1. This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
2. Sealmaster Intumescent Fire and Smoke Seals comprise a range of aluminium encased, mono ammonium phosphate based, door edge seals of the low pressure intumescent type. This certification applies to variants IF30, IF60 and IMP (without integral smoke seals) and variants N30, N60, N60S and IMN (with integral smoke seals)
3. The door seals are approved on the basis of:
 - i) A design appraisal against TS35 and TS21
 - ii) Initial type testing
 - iii) Manufacturing frequency checks
 - iv) Ageing and durability tests
 - v) Evidence of technical support
 - vi) Clear and unambiguous labeling of seals
 - vii) Production surveillance under ISO 9001: 2008
 - viii) On-going audit tests in accordance with TS35
4. These seals, of minimum dimensions 9 mm wide by 6 mm thick, are suitable to be used with:

CERTIFIRE approved FD30 single-acting, single leaf, latched or unlatched doorsets of maximum leaf dimensions 2040 mm high by 926 mm wide and of minimum thickness 42 mm. The doorset assemblies shall consist of timber faced and edged leaves with timber, cellulosic or mineral cores in timber frames (Code ITT). More information can be referred to in TS35.
5. The approved IF30, IF60 and IMP (without integral smoke seals) and variants N30, N60, N60S and IMN (with integral smoke seals) seals shall have nominal widths and cross-sectional areas of intumescent at least equal to those in the tested/approved door assembly and shall be similarly positioned.

Signed
E/167

Issued: 16th March 2006
Reissued: 18th April 2019
Valid to: 17th April 2024

Page 2 of 3



CERTIFICATE No CF 462
DIXON INTERNATIONAL GROUP LTD
(Sealmaster is a division of DIG Ltd)

SEALMASTER INTUMESCENT FIRE AND SMOKE SEALS

6. When the fire seals include smoke seals they may only be interrupted at latch (maximum 100 mm) and hinge positions. They shall otherwise be continuous around the head and vertical edges of the door.
7. The seals shall be installed in accordance with the manufacturer's instructions.
8. The approval relates to on-going production. Product and/or its immediate packaging is identified with the manufacturers' name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number (i.e. No. CF 462) and application where appropriate.

Further Information

Further information regarding the details contained in this certificate may be obtained from Sealmaster (Tel: 01223 832851)

Further information regarding CERTIFIRE certification and other approved products can be obtained from CERTIFIRE (Tel: 01925 646 777)

Signed
E/167

Issued: 16th March 2006
Reissued: 18th April 2019
Valid to: 17th April 2024

Page 3 of 3